


MORENO VALLEY STANDARD NO. MVEU-721-0

PRECAST CONCRETE PARKWAY ENCLOSURE

2' x 3' x 5' & 3' x 5' x 5'






* MIN EXCAVATION 36" x 72" x DEPTH OF BOX

NOTES:

1. USE A 2'x3'x5' FOR UP TO THREE (3) STRAIGHT SPLICES.
2. USE A 3'x5'x5' PULL BOX FOR UP TO THREE (3) JBAR SPLICES.

NOT TO SCALE

	RECOMMENDED:  1-15-10 DIVISION MANAGER DATE	CITY OF MORENO VALLEY PUBLIC WORKS DEPARTMENT - ELECTRIC UTILITY DIVISION	
	APPROVED:  1/29/14 PUBLIC WORKS DIRECTOR / DATE CITY ENGINEER	PRECAST CONCRETE PARKWAY ENCLOSURE 2' x 3' x 5' AND 3' x 5' x 5'	